



BlueShore

ENGINEERING L.L.C.

Richard W. Gilbert, P.E.

June 28, 2016

From: Catherine Hanna, EIT
To: Potential Bidders
Subject: Addendum #1, Nyack Marina Dredging RFP

The following RFP addendum is provided in response to questions received from bidders. All requirements of the original RFP shall remain in full force and effect, except as set forth in this Addendum and any other previously issued Addenda. Please acknowledge receipt of this addendum by providing a signed copy of this page with your proposal.

Question/Statement #1:

We respectfully request an extension of the bid deadline by one week.

Answer: The bid due date has been extended (by one week) to July 6, 2016.

Question/Statement #2:

On drawing C-00, GENERAL REQUIREMENTS, note 4 states, "The contractor shall provide all field surveys necessary to complete construction in accordance with these drawings by a NY licensed surveyor." On the same sheet, DREDGING, note 4 states, "The engineer of record shall perform pre-dredge and post-dredge hydrographic surveys to verify contract dredge depths have been obtained." Will the contractor be responsible for any hydrographic surveys to perform their work or can the contractor use the engineers of record's pre-dredge survey to perform their work?

Answer: The contractor may use the EOR's pre-dredge survey to perform their work but there is no guarantee that this survey will provide all the information necessary. Therefore, the contractor is responsible for any additional survey that may be needed to complete the work as shown on plans.